**Note:** This report is issued subject to the Testing and Certification Regulations of the TÜV SÜD Group and the General Terms and Conditions of Business of TÜV SÜD PSB Pte Ltd. In addition, this report is governed by the terms set out within this report.



Choose certainty.
Add value.

#### **SUBJECT:**

Testing of "SIAMP" brand WC Inlet and Outlet Valves (Set 1)

#### **TESTED FOR:**

SIAMP Ltd Lot E1, K1 Road, Cat Lai Industrial Zone Cluster 2, Thanh My Loi Ward, District 2 Ho Chi Minh City, Vietnam

Attn: Mr Huynh Minh Khuong

#### **DESCRIPTION OF SAMPLE:**

One unit of "SIAMP" Brand WC Inlet and Outlet Valves (Set 1) was received on 19/9/2012.

Set 1 (MSE Long Telescopic Vissable, Robinet 99B)

#### **TEST METHOD:**

- 1. SS 378:1996 Specification for low capacity water closet flushing cisterns up to 4.5L(max).
- 2. SS 379:1996 Specification for vitreous china water closet pans for use with low capacity water closet flushing cisterns up to 4.5L(max).
- 3 BS 1212:Part 4:1991 Specification for compact type float operated valves for water closet flushing cisterns(including floats

## PUB's Requirements issued on July 06 - Testing Requirements for Dual-Flush Low Capacity WC Flushing Cistern

- (1) Clause 2.a Volume of discharge Reduced Flush
- (2) Clause 2.b Dilution Test Reduced Flush
- (3) Clause 2.c Endurance Test 100,000 cycles Reduced Flush
- (4) Clause 2.d Load Test on Operating Mechanism Reduced Flush
- (5) Clause 2.e Paper Discharge Test Reduced Flush



Laboratory: TÜV SÜD PSB Pte. Ltd. No.1 Science Park Drive Singapore 118221 July

Phone: +65-6885 1333 Fax: +65-6776 8670 E-mail: testing@tuv-sud-psb.sg www.tuv-sud-psb.sg Co. Reg: 199002667R

Regional Head Office: TÜV SÜD Asia Pacific Pte. Ltd. 3 Science Park Drive, #04-01/05 The Franklin, Singapore 118223

Aldkhy.



#### **RESULTS:**

#### (A) Full Flush Test

#### (A1) Dimensional Measurements on WC Inlet Valves & OutLet Valves (All dimensions in mm)

Sample Reference		SIAMP Set 1	SS 378 : 1996 Requirements
Nominal size	of ballvalve	1/2"	1/2"
Internal diame	eter of warning pipe	20	19 min.
	Nominal bore	15	12
Bottom Connection	The length of effective thread after the assembly has been fixed to the cistern shell	20	Shall not be less than 12
Inlet Pipe	Diameter of flange	38	Not less than 36
	Thickness of pipe	2.6	Nowhere less than 2.0
Thickness of i pipe	nternal connection warning	1.7	1.2 minimum

### (A2) Flushing Test

	SIAMP Set 1		
Sample Reference	Before Endurance	After Endurance	SS 378 & SS379 : 1996 Requirements
Volume of discharge (litres)	4.5	4.5	4.5 (+0.0, -1.0)
Toilet paper test	Passed	Passed	
Towel test	Passed	Passed	The trap shall be cleared completely four times out of five in each test.
Ball test	Passed	Passed	
Sawdust test	Passed	Passed	The unflushed areas between the water surface and the underside of the rim shall not exceed 5000 mm <sup>2</sup>

Note: The cistern was coupled with a pedestal WC pan for the flushing test

July

Aldehy.



#### **RESULTS:**

### (A3) Physical Test

Sample Reference	SIAMP Set 1	SS 378 : 1996 Requirements
Resistance to torque (15 Nm) of flushing device	Passed	Clause 4.5.2
Antisiphonage test (Backflow)	Passed	Clause 4.15
Adjustability test of float-operated valve	Passed	Clause 4.13
Dead load test at 23 kg on push button	Passed	Clause 5.2.4
Hydraulic test on connection inlet pipe	Passed	Shall be capable of withstanding a pressure of 2 MN/m <sup>2</sup> .
Torque test on connection inlet pipe (15 Nm)	Passed	Shall be no sign of distortion of the threads or the flats of the hexagon.

### (A4) Performance of Float Operated Valve

Sample Reference	SIAMP Set 1	BS 1212 : Pt. 4 : 1991 Requirements
Inlet shank and backnuts distortion	Passed	No visible distortion of the inlet shank, backnuts or integral body flange.
Static hydraulic pressure at 20 bar for 60 seconds	Passed	Shall withstand a pressure of 20 bar for 60 seconds without leaking.
Shut-off pressure test	Passed	Shall withstand a shut-off pressure of 14 bar without passing water.
Lever deflection test after 28 days	Passed	No evidence of the valve passing water or any increase in water level.
Dynamic pressure test at 10 bar for 60 seconds	Passed	Shall show no permanent deformation or separation of any component part.

Julyaban

aldkhy.



#### **TEST RESULTS:**

#### (A5) Endurance Test of 100,000 cycles

Sample Reference	SIAMP Set 1	SS 378 : 1996 Requirements
Result		
(The water closet flushing mechanism was subjected to repeated flushing operation simulating the device in actual use)	Passed	Clause 7.3 On completion of the test, it shall not leak or show sign of defect or damage.

#### (B) Reduced Flush

Sample Reference	SIAMP Set 1	Clause 2.a - Reduced Flush Requirements
Volume of discharge – Reduced Flush	3	Shall not be more than 3 litres

Sample Reference	SIAMP Set 1	Clause 2.b - Reduced Flush Requirements
Dilution Test – Reduced Flush	Passed	Shall have no visible traces of the colouring matter in the water trap of the WC pan

Sample Reference	SIAMP Set 1	Clause 2.c - Reduced Flush Requirements
Endurance Test – 100,000 cycles – Reduced Flush	Passed	Shall not leak or show signs of defect or damage

Sample Reference	SIAMP Set 1	Clause 2.a Reduced Flush Requirements
Volume of discharge after Endurance Test – Reduced Flush	3	Shall not be more than 3 litres

Sample Reference	SIAMP Set 1	Clause 2.d Reduced Flush requirements
Load Test on Operating Mechanism	Passed	Shall not distort to such an extent that any part becomes detached or inoperative

Julyabour

Oldkhy.



#### **TEST RESULTS:**

#### (B) Reduced Flush

Sample Reference	SIAMP Set 1	SS 378 : 1996 Requirements,
Backflow test after endurance	Passed	SubClause 4.15

Sample Reference	SIAMP Set 1	Clause 2.e - Reduced Flush Requirements
Reduced Flush – Paper Discharge Test	Passed	Shall discharge from the outlet spigot of the pan all of 4 pcs of joined twin-ply papers in at least two out of the three tests

Note: The cistern was coupled with a pedestal WC pan for the flushing test



MSE Long Telescopic Vissable



Robinet 99B



**BT 40** 

Lee Ngiap Boon Associate Engineer

Chua Peck Cheong Product Manager Automotive & Industrial Group Mechanical Centre



Please note that this Report is issued under the following terms :

- 1. This report applies to the sample of the specific product/equipment given at the time of its testing/calibration. The results are not used to indicate or imply that they are applicable to other similar items. In addition, such results must not be used to indicate or imply that TÜV SÜD PSB approves, recommends or endorses the manufacturer, supplier or user of such product/equipment, or that TÜV SÜD PSB in any way "guarantees" the later performance of the product/equipment. Unless otherwise stated in this report, no tests were conducted to determine long term effects of using the specific product/equipment.
- The sample/s mentioned in this report is/are submitted/supplied/manufactured by the Client. TÜV SÜD PSB therefore assumes no responsibility for the accuracy of information on the brand name, model number, origin of manufacture, consignment or any information supplied.
- 3. Nothing in this report shall be interpreted to mean that TÜV SÜD PSB has verified or ascertained any endorsement or marks from any other testing authority or bodies that may be found on that sample.
- 4. This report shall not be reproduced wholly or in parts and no reference shall be made by the Client to TÜV SÜD PSB or to the report or results furnished by TÜV SÜD PSB in any advertisements or sales promotion.
- 5. Unless otherwise stated, the tests were carried out in TÜV SÜD PSB Pte Ltd, No.1 Science Park Drive Singapore 118221.

