



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (5) in WSD 3321/15 Pt.1 T/J(388)

17 December 2015

Approval of Float Operated Valves

Your letters dated 2nd October and 15th December 2015 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: Siamp

Country of Origin: Turkey

Brand: Siamp

Details of Fitting: Range of side entry WC inlet valve, with acetal bodies and NBR diaphragm. The inlet incorporates a strainer. Maximum working pressure 10.0 bar. For cold water use only.

Size: $\frac{3}{8}$ " BSP (M) and $\frac{1}{2}$ " BSP (M).

Model: Compact 95L

Marking: Siamp on float

WRAS Approval Number: 1403322

Installation Requirements: R001, R150, R280, R390

Expiry Date: 31 March 2019

Proviso: As the fitting has not been tested for use in contact with water intended for human consumption, the fitting can only be used in flush water supply plumbing systems only.

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in flushing water supply plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirements –

“The flushing volume of the flushing valves should be adjusted to suit the design of the toilet bowl so that wastes can be cleared effectively by a single flush.”

“The maximum flushing cistern volume including that of dual flush cisterns for use in conjunction with the fittings shall not exceed 7.5 litres per flush.”

“The fitting should be used within the range of working pressures specified by the manufacturer.” AND

“The installed fitting should not result in backflow of water that will contaminate the flushing water supply.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water supply plumbing systems.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms. K L FOK at tel. no. 2829 5657.

Yours faithfully,



(LAM Ching Man)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 E/CS(TS)1]

